



Bulletin 25

Chilled Water BTU Monitoring

Tenants are required to purchase and install the following from ROTH SOUTHEAST for BTU monitoring, and connection to the BUILDING AUTOMATION SYSTEM:

- Flow meter (SDI Series) without BTU display.
- Immersion well sensors.
- Control wire and cable.
- Connection to Mall BMS.
- Start up and commissioning.

NOTES:

- Tenants are required to install necessary immersion wells and flow meter in piping.
- High voltage wiring by Tenants.
- Tenant to run cable from meter to control panel in demark room.

CONTACT: MARTY CAPOGRECO, ROTH SOUTHEAST, (954)423-6640

